

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 8833

Dated: 06/06/2025

It is certified that an inspection team headed bySurveet Garg..... from ..Kurukshetra..... PHED inspected the Srimad Bhagwad Gita Senior Secondary School, Railway Road, Kurukshetra on ..02/06/2025.....(date of inspection) and on the basis of Water Test Report (Attached) bearing no1044 & 1045 dated...02.06.25 of (PHED Lab) certified that Srimad Bhagwad Gita Senior Secondary School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till....03-06-2026

Signature with Seal.....

Name Executive Engineer
Public Health Engg. Divn.
Designation Kurukshetra

Name & Address of the Office / Department.....

To

Srimad Bhagwad Gita Senior Secondary School
Railway Road, Kurukshetra
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer /PHED Lab/Local Bodies



Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory, Kurukshetra.
 Jal Bhawan Sector-10 Kkr. Email id:-chemist.kkra@gmail.com.

Test Report

Temp.27° C	Humidity 58%
No. : TC45602500000533 F	Sample Collected on Date : 30/05/2025
Report No.: KKR/ 02155 /5/2025	Sample Received on Date : 30/05/2025
Sender : SMB GITA SS SCHOOL Kurukshetra	Sample Location : SMB GITA SS SCHOOL Tubewell No. 1 Railway Road Kurukshetra
Customer Reference No.: 0	Sample Quantity : 1 Ltr.
Sample Description : Water	Date of Analysis Started : 30/05/2025
Sample Type : Physico-Chemical Analysis	Date of Analysis Completed : 02/06/2025
Sample No. : 1044 Date: 02/06/2025	Date of Issue : 02/06/2025

RESULTS

Parameter	Protocol used	Result	IS:10500:2012(Second revision)		Unit
			Acceptable Limit	Permissible limit in the absence of alternate source	
Colour	IS 3025Part-4: 2021	<05	5	15	Hazen
Odour	IS 3025Part-5: 2018	Agreeable	Agreeable	Agreeable	-
Taste	IS 3025Part-8: 2023	Agreeable	Agreeable	Agreeable	-
Total Dissolve Solids (180°C)	IS 3025Part-16: 2023	365	500	2000	mg/L
Total Hardness (as CaCO ₃)	IS 3025Part-21: 2009	112.14	200	600	mg/L
Calcium (as Ca)	IS 3025Part-40: 1991 RA 2019	22.47	75	200	mg/L
Magnesium (as Mg)	IS 3025Part-46: 2023	12.75	30	100	mg/L
Total Alkalinity (as CaCO ₃)	IS 3025Part-23: 2023	207.9	200	600	mg/L
Chloride (as Cl)	IS 3025Part-32: 1988 RA 2019	38.44	250	1000	mg/L
Fluoride (as F)	IS 3025Part-60: 2023	0.142	1.0	1.5	mg/L
pH (25°C)	IS 3025Part-11: RA 2022	8.06	6.5 to 8.5	No Relaxation	-
Turbidity	APHA2130 B 2023	BDL	1	5	NTU

Notes:

- The Results given above are related to the sample as received and tested in PHED Lab, Kurukshetra. Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Reviewed By

Nisha Saini
 Authorised Signatory
 PHED Water Testing Laboratory
 Kurukshetra



Govt. of Haryana
Public Health Engineering Department, Water Testing Laboratory, Kurukshetra.
 Jal Bhawan Sector-10 Kkr, Email Id:-chemist.kkra@gmail.com.

Test Report

Temp.27° C

Humidity 58%

URL No. :	TC45602500000534 F	Sample Collected on Date :	30/05/2025
Test Report No.:	KKR/ 02157 /5/2025	Sample Received on Date :	30/05/2025
Sender . :	SMB GITA SS SCHOOL Kurukshetra	Sample Location :	SMB GITA SS SCHOOL Tubewell No. 2 Railway Road Kurukshetra
Customer Reference No. : 0		Sample Quantity :	1 Ltr.
Sample Description :	Water	Date of Analysis Started :	30/05/2025
Sample Type :	Physico-Chemical Analysis	Date of Analysis Completed :	02/06/2025
Memo No. :	1045 Date: 02/06/2025	Date of Issue :	02/06/2025


RESULTS

S.NO.	Parameter	Protocol used	Result	IS:10500:2012(Second revision)		Unit
				Acceptable Limit	Permissible limit in the absence of alternate source	
1	Colour	IS 3025Part-4: 2021	<05	5	15	Hazen
2	Odour	IS 3025Part-5: 2018	Agreeable	Agreeable	Agreeable	-
3	Taste	IS 3025Part-8: 2023	Agreeable	Agreeable	Agreeable	-
4	Total Dissolve Solids (180°C)	IS 3025Part-16: 2023	341	500	2000	mg/L
5	Total Hardness (as CaCO ₃)	IS 3025Part-21: 2009	130.83	200	600	mg/L
6	Calcium (as Ca)	IS 3025Part-40: 1991 RA 2019	38.70	75	200	mg/L
7	Magnesium (as Mg)	IS 3025Part-46: 2023	10.61	30	100	mg/L
8	Total Alkalinity (as CaCO ₃)	IS 3025Part-23: 2023	207.90	200	600	mg/L
9	Chloride (as Cl)	IS 3025Part-32: 1988 RA 2019	23.06	250	1000	mg/L
10	Fluoride (as F)	IS 3025Part-60: 2023	0.231	1.0	1.5	mg/L
11	pH (25°C)	IS 3025Part-11: RA 2022	8.01	6.5 to 8.5	No Relaxation	-
E	Turbidity	APHA2130 B 2023	BDL	1	5	NTU

Notes:

- The Results given above are related to the sample as received and tested in PHED Lab, Kurukshetra. Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Reviewed By



End of the Report

PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY ,KURUKSHETRA

Website :- <https://phedharyana.gov.in/>

Memo No:- 1041

Date:- 02/06/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	KKR/02154/5/2025	Sample Details	Date & Time
Sample Classification:	Private	Collected By	MAHAVIR,9996507777
Sender:	SMB GITA SS SCHOOL	Collection Date	28/05/2025 at 10:43
Location :-	, RAILWAY ROAD KURUKSHETRA	Received at lab	30/05/2025 at 15:36
Latitude :-	76.839653	Tested at Lab	02/06/2025
Longitude :-	29.967720		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- * The test report can't be regenerated in whole or part thereof without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING " to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters, the water sample is found "POTABLE"



NISHA SAINI,CHEMIST
 PUBLIC HEALTH ENGINEERING DEPARTMENT
 DISTRICT WATER TESTING
 LABORATORY,KURUKSHETRA
 email:-chemist.kkra@phedharyana.gov.in

-----End of Report-----

PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY ,KURUKSHETRA

Website :- <https://phedharyana.gov.in/>

Memo No:- 1042

Date:- 02/06/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	KKR/02157/5/2025	Sample Details	Date & Time
Sample Classification:	Private	Collected By	MAHAVIR,9996507777
Sender:	SMB GITA SS SCHOOL	Collection Date	28/05/2025 at 11:00
Location :-	, TUBEWELL NO. 2 RAILWAY ROAD, KURUKSHETRA	Received at lab	30/05/2025 at 15:36
Latitude :-	76.840160	Tested at Lab	02/06/2025
Longitude :-	29.967687		

Test Result (As Per BIS 10500 :2012)				
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in KURUKSHETRA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
 Based on the tested parameters, the water sample is found "**POTABLE**"




NISHA SAINI, CHEMIST
 PUBLIC HEALTH ENGINEERING DEPARTMENT
 DISTRICT WATER TESTING
 LABORATORY, KURUKSHETRA
 email:-chemist.kkra@phedharyana.gov.in

-----End of Report-----